

DIVISION OF INDUSTRY SERVICES PO BOX 7162 MADISON WI 53707-7162 Contact Through Relay http://dsps.wi.gov/programs/industry-services www.wisconsin.gov

> Scott Walker, Governor Dave Ross, Secretary

June 30, 2015

Identification Numbers

Transaction ID No. 2553163 Site ID No.

Please refer to both identification numbers, above, in all correspondence with the agency.

CUST ID No. 1319928

ED WEBER SKYLINE CORPORATION 2520 BYPASS RD PO BOX 743 ELKHART IN 46515

CONDITIONAL APPROVAL

PLAN APPROVAL EXPIRES: 06/30/2020

Re: Description: PREFABRICATED PLUMBING SYSTEM

Manufacturer: SKYLINE CORPORATION

Product Name: PREFABRICATED PLUMBING SYSTEM (trans id 2553163)

Model Number(s): TUB DRAIN & VENT FIGURES 1 THRU 4, LAUNDRY TUB FIGURE 1,

WASHER FIGURE 1, SHOWER DRAIN & VENT FIGURES 1 THRU 4, SINGLE LAV FIGURE 1, SINGLE LAV FIGURE 1, DOUBLE LAV. FIGURE 1, TOLET DRAIN CONNECTIONS FIGURES 1 THRU 6, VENTING DETAILS FIGURES 1 THRU 3, KITCHEN DRAIN CONNECTIONS FIGURES 1 THRU 4, AND WATER

SUPPLIES FIGURES 1 THRU 8.

Product File No: 20150149

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of June 2020.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 35 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This approval is for only the prefabricated plumbing system as defined herein. "Prefabricated
 Plumbing" means concealed drain piping, vent piping or water supply piping or a combination of these
 types of piping, contained in a modular building component, which will not be visible for inspection
 when delivered to the final site of installation.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

ED WEBER Page 2 6/30/2015

Sincerely,

Timothy J. Lamb
Plumbing Plan Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
Madison WI 53703-2658
608-266-9647 Phone
608-267-9723 Fax
tim.lamb@wi.gov E-mail

Fee Required \$ 125.00 Fee Received \$ 125.00 Balance Due \$ 0.00

WiSMART code: 7657